

1

2

3

4

5

6


FIELD

REMOTE I/O

MCC BUCKET


PANEL

PRESSURE SWITCH AIR RECEIVER 1



120VAC


RIO-10 PANEL TB



13


RIO-10 RACK 2 SLOT 3 LINE 70632

AIR COMPRESSOR 1 CB-80.1.1




460V/3PH/60HZ

CB-80.1.1 110 AMP




EP-601

AIR DRYER 1 LCP-80.2.1




120VAC

UPS POWER DISTRIBUTION PANEL EP-615




AIR RECEIVER 1 BLOW DOWN SOLENOID



120VAC



UPS POWER DISTRIBUTION PANEL EP-615



TAG	DESCRIPTION	MANUFACTURER	MODEL NO.	CALIBRATION
PSL-80.1.1	PRESSURE SWITCH LOW	X	X	X
M-80.1.1	MOTOR	X	X	X
LCP-80.2.1	LOCAL CONTROL PANEL	X	X	X
EV-80.1.1	SOLENOID VALVE	ASCO	X	X

THIS DRAWING IS COPY RIGHTED... FOR HIS PERSONAL USE WITHOUT THE SIGNED WRITTEN CONSENT OF ANDRITZ-RUTHNER, INC. IT MUST NOT BE COPIED NOR MADE AVAILABLE TO THIRD PARTIES...

RELEASED 12/08/06 REVISION-0



DATE:	3/21/06
DRAWN BY:	BB
CHECKED BY:	
APPROVED BY:	
SCALE:	NONE
SIZE:	15224E1846
REV	0
REVISION	FOR FINAL REVIEW/BUILDING PERMIT
DATE	12/08/06

CITY OF STAMFORD CONNECTICUT
SOLIDS DRYING PROJECT
PELLETIZING TRAIN GROUP 080
LOOP DIAGRAM
PROJECT NUMBER 1524
DRAWING NUMBER EI-846
SHEET 1 OF 2