

1

2

3

4

5

6


FIELD

REMOTE I/O

MCC BUCKET


PANEL

PRESSURE SWITCH
AIR RECEIVER 2



120VAC


RIO-10
PANEL TB



RIO-10
RACK 2
SLOT 4
LINE 70715


7

AIR RECEIVER
2 BLOW DOWN
SOLENOID



120VAC




UPS POWER DISTRIBUTION
PANEL EP-615



TAG	DESCRIPTION	MANUFACTURER	MODEL NO.	CALIBRATION
PSL-80.1.2	PRESSURE SWITCH LOW	X	X	X
EV-80.1.2	SOLENOID VALVE	ASCO	X	X

THIS DRAWING IS A TRADE SECRET AND ONLY ENTRUSTED TO THE RECEIVER FOR HIS PERSONAL USE. WITHOUT THE SIGNED WRITTEN CONSENT OF ANDRITZ-RUTHNER, INC., IT MUST NOT BE COPIED NOR MADE AVAILABLE TO THIRD PARTIES. INCLUDING COMPETITORS, NOR MADE ACCESSIBLE TO SUCH PARTIES. ANY ILLEGAL USE BY THE RECEIVER OR THIRD PARTIES FOR WHICH HE IS RESPONSIBLE CAN CONSTITUTE A CAUSE FOR LEGAL ACTION. THIS DRAWING MUST BE RETURNED ON REQUEST OF THE COMPANY.

RELEASED 12/08/06
REVISION-0



DATE:	3/21/06
DATE:	
DATE:	
FILE:	15224E1847
SCALE:	NONE
SIZE:	
REV	0
REVISION	FOR FINAL REVIEW/BUILDING PERMIT
DATE	12/08/06

DDSD40

CITY OF STAMFORD CONNECTICUT
SOLIDS DRYING PROJECT
PELLETIZING TRAIN GROUP 080
LOOP DIAGRAM

PROJECT NUMBER
1524
DRAWING NUMBER
EI-847
SHEET 2 OF 2