


- NOTES:**
- 1) OVERLOADS ARE SMP-1 SOLID STATE, CLASS 20, MANUAL RESET, UNLESS NOTED OTHERWISE.
 - 2) E3 PLUS OVERLOAD WITH CURRENT MONITOR.
 - 3) LINE REACTORS ARE 5%.
 - 4) ALL MCC CIRCUIT BREAKERS SHALL BE HMCP TYPE OR EQUAL UNLESS OTHERWISE NOTED
 - 5) CIRCUIT BREAKER TO BE THERMAL MAGNETIC
 - 6) OVERLOADS & CIRCUIT BREAKER SIZES TO MANUFACTURERS RECOMENDATIONS



DATE:	12/27/05
DRAWN BY:	SSD
CHECKED BY:	
APPROVED BY:	
SCALE:	NONE
FILE:	1524EP601
REV	REV
1	UPDATE MOTOR HP AND DELETED M-16.3.1
0	FOR FINAL REVIEW/BUILDING PERMIT
B	REVISED PER MCC ELEVATION DRAWING
	REVISION
	DATE
	8/31/06
	06/05/06
	2/21/06

CITY OF STAMFORD CONNECTICUT
SOLIDS DRYING PROJECT
JOB NAME
TITLE
MCC ONE LINE
DIAGRAM, SHEET 1 OF 2
PROJECT NUMBER
1524
DRAWING NUMBER
EP-601
SHEET 1 OF 2

RELEASED 12/08/06
REVISION - 1

THIS DRAWING IS COPY RIGHTED
FOR HIS PERSONAL USE WITHOUT THE SIGNED WRITTEN CONSENT OF ANDRITZ-RUTHNER, INC. IT MUST NOT BE COPIED NOR MADE AVAILABLE TO THIRD PARTIES, INCLUDING COMPETITORS, NOR MADE ACCESSIBLE TO SUCH PARTIES. ANY ILLEGAL USE BY THE RECEIVER OR THIRD PARTIES FOR WHICH HE IS RESPONSIBLE CAN CONSTITUTE A CAUSE FOR LEGAL ACTION. THIS DRAWING MUST BE RETURNED ON REQUEST OF THE COMPANY.

