

EON

DeviceNet TRUNKLINE NETWORK 1

TO EP-709

M-1.1.1
COMBUSTION
BLOWER

| | |
|--------------------|-------|
| MCC Location: | 1A |
| DeviceNet Type: | DSA2 |
| DeviceNet Network: | 1 |
| Multi-Node? | N |
| DeviceNet Node: | 1 |
| Current Draw: | 0.125 |

TERMINATOR
121 OHM

PM3000
POWER
MONITOR

| | |
|--------------------|--------|
| MCC Location: | 1C |
| DeviceNet Type: | PM3000 |
| DeviceNet Network: | 1 |
| Multi-Node? | N |
| DeviceNet Node: | 2 |
| Current Draw: | 0.125 |

-

| | |
|--------------------|---|
| MCC Location: | - |
| DeviceNet Type: | - |
| DeviceNet Network: | - |
| Multi-Node? | - |
| DeviceNet Node: | - |
| Current Draw: | - |

-

| | |
|--------------------|---|
| MCC Location: | - |
| DeviceNet Type: | - |
| DeviceNet Network: | - |
| Multi-Node? | - |
| DeviceNet Node: | - |
| Current Draw: | - |

-

| | |
|--------------------|---|
| MCC Location: | - |
| DeviceNet Type: | - |
| DeviceNet Network: | - |
| Multi-Node? | - |
| DeviceNet Node: | - |
| Current Draw: | - |

-

| | |
|--------------------|---|
| MCC Location: | - |
| DeviceNet Type: | - |
| DeviceNet Network: | - |
| Multi-Node? | - |
| DeviceNet Node: | - |
| Current Draw: | - |

M-2.1.1
DRUM
DRIVE

| | |
|--------------------|--------|
| MCC Location: | 2A |
| DeviceNet Type: | E3PLUS |
| DeviceNet Network: | 1 |
| Multi-Node? | N |
| DeviceNet Node: | 3 |
| Current Draw: | 0.125 |

-

| | |
|--------------------|---|
| MCC Location: | - |
| DeviceNet Type: | - |
| DeviceNet Network: | - |
| Multi-Node? | - |
| DeviceNet Node: | - |
| Current Draw: | - |

M-6.1.1
PRESEPERATOR
ROTARY
VALVE

| | |
|--------------------|-------|
| MCC Location: | 2E |
| DeviceNet Type: | DSA2 |
| DeviceNet Network: | 1 |
| Multi-Node? | N |
| DeviceNet Node: | 4 |
| Current Draw: | 0.125 |

M-7.1.1
POLYCYCLONE
SCREW
CONVEYOR

| | |
|--------------------|-------|
| MCC Location: | 2G |
| DeviceNet Type: | DSA2 |
| DeviceNet Network: | 1 |
| Multi-Node? | N |
| DeviceNet Node: | 5 |
| Current Draw: | 0.125 |

M-8.1.1
SCREEN
FEED
ROTARY
VALVE

| | |
|--------------------|-------|
| MCC Location: | 2J |
| DeviceNet Type: | DSA2 |
| DeviceNet Network: | 1 |
| Multi-Node? | N |
| DeviceNet Node: | 6 |
| Current Draw: | 0.125 |

M-9.1.1
SHAKER
SCREEN

| | |
|--------------------|-------|
| MCC Location: | 2L |
| DeviceNet Type: | DSA2 |
| DeviceNet Network: | 1 |
| Multi-Node? | N |
| DeviceNet Node: | 7 |
| Current Draw: | 0.125 |

M-5.1.1
MAIN
I.D.
FAN

| | |
|--------------------|-------|
| MCC Location: | 3A |
| DeviceNet Type: | DCOMM |
| DeviceNet Network: | 1 |
| Multi-Node? | N |
| DeviceNet Node: | 8 |
| Current Draw: | 0.120 |

M-5.1.1
MAIN
I.D.
FAN

| | |
|--------------------|-------|
| MCC Location: | 3A |
| DeviceNet Type: | DSA2 |
| DeviceNet Network: | 1 |
| Multi-Node? | N |
| DeviceNet Node: | 9 |
| Current Draw: | 0.125 |

-

| | |
|--------------------|---|
| MCC Location: | - |
| DeviceNet Type: | - |
| DeviceNet Network: | - |
| Multi-Node? | - |
| DeviceNet Node: | - |
| Current Draw: | - |

-

| | |
|--------------------|---|
| MCC Location: | - |
| DeviceNet Type: | - |
| DeviceNet Network: | - |
| Multi-Node? | - |
| DeviceNet Node: | - |
| Current Draw: | - |

-




| | |
|--------------------|---|
| MCC Location: | - |
| DeviceNet Type: | - |
| DeviceNet Network: | - |
| Multi-Node? | - |
| DeviceNet Node: | - |
| Current Draw: | - |

-

| | |
|--------------------|---|
| MCC Location: | - |
| DeviceNet Type: | - |
| DeviceNet Network: | - |
| Multi-Node? | - |
| DeviceNet Node: | - |
| Current Draw: | - |

THIS DRAWING IS A TRADE SECRET AND ONLY ENTRUSTED TO THE RECEIVER FOR HIS PERSONAL USE. WITHOUT THE SIGNED WRITTEN CONSENT OF ANDRITZ-RUTHNER, INC., IT MUST NOT BE COPIED NOR MADE AVAILABLE TO THIRD PARTIES. INCLUDING COMPETITORS, NOR MADE ACCESSIBLE TO SUCH PARTIES. ANY ILLEGAL USE BY THE RECEIVER OR THIRD PARTIES FOR WHICH HE IS RESPONSIBLE CAN CONSTITUTE A CAUSE FOR LEGAL ACTION. THIS DRAWING MUST BE RETURNED ON REQUEST OF THE COMPANY.

RELEASED 12/08/06
REVISION - 0



| | |
|----------------------------------|----------|
| DATE | 06/05/06 |
| FOR FINAL REVIEW/BUILDING PERMIT | 0 |
| REVISION | 0 |

| | |
|--------------|-----------|
| DATE | 12/27/05 |
| SSD | |
| CHECKED BY: | |
| APPROVED BY: | |
| SCALE: | NONE |
| FILE | 1524EP708 |
| SIZE | |

| | |
|----------------|--|
| JOB NAME | CITY OF STAMFORD CONNECTICUT SOLIDS DRYING PROJECT |
| TITLE | MCC DEVICENET NETWORK |
| PROJECT NUMBER | 1524 |
| DRAWING NUMBER | EP-708 |
| SHEET | 1 OF 5 |