



MAIN FLOOR PLAN
1/4"=1'-0"

- NOTES:**
1. SLOPE DRAINAGE LINES AT 2%
 2. REFER TO SPECIFICATION SECTION 15060 FOR PIPING LEGEND (SCHEDULE).
 3. THE PROCESS DRAIN LINES FROM THE VENTURI SCRUBBER AND SATURATOR ARE ABOVE THE PROCESS DRAIN LINES FROM THE FLOOR DRAINS.
 4. PRIME THE RUNNING TRAP FROM THE ELECTRONIC TRAP PRIMER LOCATED IN THE WASHROOM. REFER TO DWG B-2411 FOR ADDITIONAL INFORMATION.
 5. DRYER EQUIPMENT AND PLATFORMS PROVIDED BY ANDRITZ RE SHOWN FOR REFERENCE ONLY. REFER TO ANDRITZ DRAWINGS FOR EXACT LOCATION AND ELEVATION OF EQUIPMENT.
 6. FOR PIPE TYPE REFER TO PIPING SCHEDULE.

THESE RECORD DOCUMENTS HAVE BEEN PREPARED BASED ON THE INFORMATION PROVIDED BY OTHERS. THE DESIGN PROFESSIONAL HAS NOT VERIFIED THE ACCURACY AND/OR COMPLETENESS OF THIS INFORMATION AND SHALL NOT BE RESPONSIBLE FOR ANY ERRORS OR OMISSIONS WHICH MAY BE INCORPORATED HEREIN AS A RESULT.

	RECORD DRAWING RE-ISSUED FOR CONSTRUCTION ISSUED FOR CONSTRUCTION FOR FINAL REVIEW/ BUILDING PERMIT	BG PW BG PW BG DL BG BG	APVD BY DL BG	
	01/20/08 09/09/06 07/04/06 06/05/06	DSGN NO.	3 2 1 0	DATE NO.
	S LAROCQUE S LAROCQUE D LYNCH B GACKSTATTER	DR CHK APVD	S LAROCQUE D LYNCH B GACKSTATTER	REUSE OF DOCUMENTS: THIS DOCUMENT AND THE IDEAS AND DESIGNS INCORPORATED HEREIN, AS AN INSTRUMENT OF PROFESSIONAL SERVICE, IS THE PROPERTY OF CH2M HILL AND IS NOT TO BE USED, IN WHOLE OR IN PART, FOR ANY OTHER PROJECT WITHOUT THE WRITTEN AUTHORIZATION OF CH2M HILL. © CH2M HILL 2004. ALL RIGHTS RESERVED.
	STAMFORD WATER POLLUTION CONTROL AUTHORITY SOLIDS DRYING PROJECT	MECHANICAL PROCESS DRAINAGE MAIN FLOOR PLAN	VERIFY SCALE BAR IS ONE INCH ON ORIGINAL DRAWING.	
DATE PROJ DWG SHEET	JUNE 2006 334058 M-2401	FILENAME: stm2401_334058.dgn MODIFIED DATE:	MODIFIED TIME:	