


1 2 3 4 5 6

A B C D E



TE/TT
153-4
OUTSIDE AIR
TEMPERATURE SENSOR

COUNTER BALANCED
BACKDRAFT DAMPER
SET TO OPEN INWARD
AT 0.15 IN WG
SIZE TO MATCH LOUVER
REFER TO ARCHITECTURAL DWG
FOR ELEVATION LOCATION

STAIR
NO. 4

STORAGE
AREA

15458

3

4

5

SOLIDS DRYING
ROOM

LOADING AREA

THERMOSTAT
FOR EF424-01 (NEMA 4X ENCLOSURE)

ROOM TEMPERATURE SENSOR
FOR AHU424-01 (NEMA 4X ENCLOSURE)
(PACKAGED WITH UNIT)

4" OA TO
CAKE BIN
(400) C/W
BALANCING DAMPER
15458

4" OA TO
SCREW CONVEYOR
(400) C/W
BALANCING DAMPER
15458

12" STAINLESS STEEL
DUCT TO FUGITIVE DUST SYSTEM
(2000)
BY DRYER SYSTEM SUPPLIER

24"x16" EG
TYP OF 7
(1100)
C/W BALANCING DAMPER
ON DUCT SLEEVE SIZED
TO MATCH GRILLE

BY DRYER
SYSTEM
SUPPLIER

SLOPE 8" DUCT
TOWARD CAKE BIN
AND SCREW CONVEYOR

12" OA
CL EL. 39.00
BY CONTRACTOR

14" OA

22" OA

ALUMINUM

FRP

22" OA

18" OA

16" OA

12" OA

48" OA FROM
ABOVE AND DOWN
TO ODOR CONTROL AREA
SEE DWGS B-2401 AND B-2402
FOR CONTINUATION

NOTES:

1. DRYER EQUIPMENT AND PLATFORMS PROVIDED BY ANDRITZ ARE SHOWN FOR REFERENCE ONLY. REFER TO ANDRITZ DRAWINGS FOR EXACT LOCATION AND ELEVATION OF EQUIPMENT.

THESE RECORD DOCUMENTS HAVE BEEN PREPARED BASED ON THE INFORMATION PROVIDED BY OTHERS. THE DESIGN PROFESSIONAL HAS NOT VERIFIED THE ACCURACY AND/OR COMPLETENESS OF THIS INFORMATION AND SHALL NOT BE RESPONSIBLE FOR ANY ERRORS OR OMISSIONS WHICH MAY BE INCORPORATED HEREIN AS A RESULT.

MAIN FLOOR PLAN
1/4"=1'-0"

| | | | |
|--------------------------------------|-----------|------------------------------------------------------------------|----------------|
| RECORD DRAWING | | APVD | B. GACKSTATTER |
| RE-ISSUED FOR CONSTRUCTION | | CHK | M. RAHMAN |
| ISSUED FOR CONSTRUCTION | | DR | S. LAROCQUE |
| FOR FINAL REVIEW/ BUILDING PERMIT | | REVISION | |
| NO. | DATE | NO. | DATE |
| 3 | 01/20/08 | 3 | 01/20/08 |
| 2 | 09/09/06 | 2 | 09/09/06 |
| 1 | 07/04/06 | 1 | 07/04/06 |
| 0 | 06/05/06 | 0 | 06/05/06 |
| STAMFORD WPCA | | STAMFORD WATER POLLUTION CONTROL AUTHORITY SOLIDS DRYING PROJECT | |
| CH2MHILL | | BUILDING SERVICES ODOR CONTROL GROUND FLOOR PLAN | |
| VERIFY SCALE | | | |
| BAR IS ONE INCH ON ORIGINAL DRAWING. | | | |
| DATE | JUNE 2006 | DWG | B-2400 |
| PROJ | 334058 | SHEET | B2 |