



VENTILATION CONTROL NARRATIVE FOR EF424-01

SWITCH	LOCATION	CONTROLLER		SET POINT	EQUIPMENT INTERLOCKS	REMARKS	
		STATUS	SENSING ELEMENT				
HAND/OFF/AUTO	LOCAL	HAND			EF424-01		
		OFF			ON		
		AUTO	THERMOSTAT	T < 90F		OFF	
				T ≥ 90F		ON	HEAT RELIEF VENTILATION

THESE RECORD DOCUMENTS HAVE BEEN PREPARED BASED ON THE INFORMATION PROVIDED BY OTHERS. THE DESIGN PROFESSIONAL HAS NOT VERIFIED THE ACCURACY AND/OR COMPLETENESS OF THIS INFORMATION AND SHALL NOT BE RESPONSIBLE FOR ANY ERRORS OR OMISSIONS WHICH MAY BE INCORPORATED HEREIN AS A RESULT.

STAMFORD WATER POLLUTION CONTROL AUTHORITY
SOLIDS DRYING PROJECT

BUILDING SERVICES
AIR FLOW AND ODOR CONTROL SCHEMATIC

RECORD DRAWING RE-ISSUED FOR CONSTRUCTION ISSUED FOR CONSTRUCTION FOR FINAL REVIEW/ BUILDING PERMIT	REVISION CHK APVD
NO. DATE	DR
3 01/20/08 2 09/09/06 1 07/04/06 0 06/05/06	S. LAROCQUE M. RAHMAN B. GACKSTATTER

VERIFY SCALE
BAR IS ONE INCH ON ORIGINAL DRAWING.

DATE	JUNE 2006
PROJ	334058
DWG	B-2407
SHEET	B9

© CH2M HILL 2004. ALL RIGHTS RESERVED.